

# Certificate



Functional  
Safety

www.tuv.com  
ID 060000000

**No.: 968/FSP 1782.06/25**

<b>Product tested</b>	Software component for temporal and spatial separation of applications	<b>Certificate holder</b>	Renesas Electronics Corporation 3-2-24 Toyosu Koto-ku Tokyo 135-0061 Japan
<b>Type designation</b>	Functional Safety Platform Software supporting non-safety applications as listed in the current revision list.		
<b>Codes and standards</b>	IEC 61508 Parts 1-3:2010		
<b>Intended application</b>	The Renesas Functional Safety Platform Software complies with the requirements of SC 3 according to IEC 61508. Hence this product can be used to support the integrator to achieve a freedom from interference between multiple safety and non-safety applications up to SIL 3 according to IEC 61508. The claimed diagnostic coverage of 99% (high) for RAM error detection by block replication, 90% (medium) for the memory fault detection for control registers of on-chip peripherals and 99% (high) for the combination of logical and temporal monitoring can be confirmed.		
<b>Specific requirements</b>	The instructions of the associated user and safety manuals shall be considered.		

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP1 V3.0:2020 in its actual version, whose results are documented in Report No. 968/FSP 1782.06/25 dated 2025-04-08. This certificate is valid only for products, which are identical with the product tested. Issued by the certification body accredited by DAkkS according to DIN EN ISO/IEC 17065. The accreditation is only valid for the scope listed in the annex to the accreditation certificate D-ZE-11052-02-00.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2025-04-15

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Thomas Steffens